

DUCT LEAKAGE TEST Page 2

Date of Test: October 31, 2014 Test File:

Data Points - Data Entered Manually:

Duct Pressure (Pa)	Fan Pressure (Pa)	Fan Flow (CFM)	% Error	Fan Configuration
0.0	n/a			
-25.0	-62.3	325	10.4	Ring 1
-25.0	-277.0	263	-10.4	Ring 2
0.0	n/a			

Comments